


Living with the Solar Energy Transformation Program (SETuP)

Isolated Power Systems Connect 26 – 29 July 2022

Power and Water Corporation

Gas supply | Electricity distribution | Water and sewerage services



Power and Water Corporation




PowerWater

Indigenous Essential Services Program

indigenous

essential services

- NTG subsidised service delivery
- Not for profit subsidiary
- End-to-end electricity services
- 72 remote Aboriginal communities
- 79 outstations (homeland settlements)
- Across 1.3 million square kilometres
- Approx 36,000 residents
- Majority public housing, NTG services
- 52 isolated diesel grids, ~\$29M p.a. diesel budget




Solar Energy Transformation Program (SETuP)

- Building on 20 years of experience with solar PV
- 10MW of utility solar PV, 25 IES communities
- ARENA funding and NTG loans \$59M
- Transformative scale
- Mass rollout to achieve 15% diesel saving
- Pilot of solar plus storage for 50% savings
- Cloud forecasting trial


Docker Rive


• Evaluation and knowledge sharing



Publications available online

Solar energy transformation program | Power and Water Corporation (powerwater.com.au)





OUR FLEET 83 ENGINES

• 4 Hino - J08 (138 kW)- J13 (150kW)

11 Detroit - Series 60 (240 kW to 320 kW)

28 Caterpillars – C9 (220 kW) to 3516 (1600 kW)

• 8 MTU - 6R1600 (248 kW) to 12V4000 (1280 kM/

• 32 Cummins – QSL 9 (200 kW) to QSK 60 (1500 kW)

Minimum Load settings

DETROIT

Series 60 – 30% or 40%
with BESS installed

HINO

- ■J08 20%
- ■J13 20%

• MTU

- 6R1600 10%
- 10V1600 10%
- 12V1600 10%
- 12V2000 30% New HPCR 10%
- 12V4000 28%

Minimum Load settings

CUMMINS

QSL 9 – 10%

- NTA855 40%
- QSX15 40%

KTA19 – 40%

- QSX 23 10 and 30%
- QST30 40%

KTA50 – 40%

QSK50 – 10%


QSK 60 – 40%

CATEPILLAR

- C9 50%
- C15 30%
- C18-40%
- C32 30%
- 3412 40%
- 3508 50%
- 3512 40% at 1500 rpm and 50% at 1000 rpm
- 3516 40% at 1500 rpm and 50% at 1000 rpm

W	HOLE	Community	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	YTD % PV
	F LIFE EF	Maningrida	22.2%	21.6%	20.1%	17.3%	17.0%	13.7%	12.2%	14.7%	16.1%	17.0%	18.8%	17.6%	17.4%
		Ramingining	23.5%	23.8%	20.9%	18.4%	15.4%	14.3%	14.9%	14.1%	14.5%	16.3%	17.4%	18.5%	17.7%
KE		Yuendumu	13.2%	12.2%	10.9%	15.1%	15.5%	13.7%	12.5%	14.2%	11.9%	14.1%	13.0%	12.2%	13.2%
		Lajamanu	17.1%	18.2%	17.2%	19.5%	17.2%	16.6%	17.2%	15.4%	15.7%	20.2%	18.8%	16.7%	17.5%
		Docker River	9.2%	12.2%	14.0%	13.5%	12.8%	11.9%	11.3%	12.4%	11.7%	10.6%	10.2%	9.5%	11.6%
		Kintore	25.2%	27.5%	27.3%	20.2%	19.5%	16.8%	13.6%	16.1%	16.5%	21.8%	17.5%	17.7%	20.0%
		Arlparra	12.4%	20.0%	21.5%	17.8%	15.9%	12.5%	14.4%	16.8%	15.7%	21.3%	19.0%	11.2%	16.5%
		Areyonga	12.1%	16.7%	19.3%	19.0%	11.8%	7.1%	8.0%	11.1%	12.5%	14.5%	12.8%	8.7%	12.8%
		Mt Liebig	11.9%	14.1%	14.0%	11.8%	10.6%	7.1%	8.0%	9.9%	9.2%	11.1%	11.0%	8.3%	10.6%
		Nyirripi	28.7%	30.3%	33.1%	7.5%	29.3%	26.4%	25.3%	25.8%	26.4%	31.1%	28.8%	26.1%	26.6%
		Daly River	62.0%	58.6%	50.0%	45.1%	43.9%	46.4%	49.0%	45.8%	35.1%	37.1%	46.2%	53.3%	47.7%
		Apatula	11.4%	12.3%	13.9%	16.1%	16.8%	13.2%	14.2%	17.7%	17.1%	13.9%	11.8%	12.2%	14.2%
		Milyakburra	20.4%	20.2%	23.4%	20.8%	17.7%	14.4%	15.6%	14.8%	15.4%	16.7%	17.4%	19.2%	18.0%
		Minyerri	18.6%	19.0%	15.2%	10.2%	10.4%	9.4%	7.7%	9.7%	8.4%	12.0%	14.2%	12.9%	12.3%
		Atitjere	16.7%	24.3%	31.6%	33.0%	27.2%	30.2%	30.2%	32.8%	30.8%	29.5%	19.1%	13.8%	26.6%
		Titjikala	31.6%	30.0%	39.7%	39.8%	20.8%	19.8%	21.0%	32.6%	46.3%	54.0%	48.4%	34.1%	34.8%
		Milingimbi	17.9%	20.0%	19.5%	18.2%	16.1%	13.2%	13.3%	13.4%	14.3%	13.6%	15.5%	16.4%	15.9%
		Minjilang	14.0%	14.7%	14.8%	13.2%	11.2%	8.5%	8.5%	8.9%	7.5%	10.9%	11.1%	11.9%	11.3%
		Galiwinku	15.1%	16.2%	16.9%	14.4%	14.0%	11.6%	10.9%	12.6%	12.6%	13.3%	13.7%	15.1%	13.9%
		Warruwi	18.3%	18.9%	18.6%	16.1%	13.7%	11.3%	11.4%	12.4%	13.3%	14.9%	16.4%	15.9%	15.1%
		Ngukurr	12.5%	13.8%	12.3%	10.9%	11.2%	10.7%	11.3%	11.1%	11.4%	12.7%	13.4%	12.7%	12.0%
		Wurrumiyanga	23.8%	23.8%	20.9%	17.2%	18.2%	15.9%	13.7%	14.2%	14.5%	17.8%	19.5%	19.7%	18.3%
		Gapuwiyak	20.4%	20.9%	22.4%	19.6%	15.8%	14.3%	12.9%	9.1%	12.8%	14.8%	12.2%	17.6%	16.1%
		Bulman	11.3%	11.5%	9.7%	9.2%	9.6%	8.2%	8.6%	7.5%	9.5%	9.8%	9.3%	7.6%	9.3%
		Gunbalanya	7.7%	13.0%	16.7%	16.6%	14.7%	13.9%	15.0%	15.6%	16.2%	16.5%	15.4%	14.7%	14.7%


PV Total MWh 40866



Power and Water Corporation

Wet Season and REF

Community	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22 YTD % PV	
Maningrida	17.7%	18.0%	17.7%	15.3%	15.3%	11.9%	9.0%	14.1%	15.2%	14.8%	17.1%	15.6%	15.1%
Ramingining	21.5%	19.0%	17.7%	15.7%	14.0%	13.6%	13.6%	14.0%	14.8%	14.9%	15.6%	17.0%	15.9%
Daly River	53.0%	53.9% <mark></mark>	48.7%	41.8%	45.7%	47.7%	48.2%	48.5%	43.8%	40.0%	44.8%	49.1%	47.1%
Milyakburra	22.8%	23.5%	22.9%	18.2%	16.1%	12.4%	15.3%	15.2%	16.1%	16.4%	18.4%	18.3%	18.0%
Milingimbi	18.7%	20.0%	19.0%	15.7%	15.1%	12.0%	13.1%	14.3%	15.7%	10.5%	14.4%	15.0%	15.3%
Minjilang	12.4%	15.0% <mark></mark>	14.4%	12.2%	10.1%	8.0%	8.4%	9.5%	8.9%	11.1%	11.0%	11.2%	11.0%
Galiwinku	11.8%	17.1%	16.0%	13.0%	13.0%	10.4%	10.4%	12.2%	12.5%	11.5%	11.5%	13.5%	12.8%
Warruwi	15.5%	16.9%	15.6%	11.6%	12.4%	10.6%	11.0%	12.6%	13.5%	14.1%	15.2%	14.5%	<mark>13.6%</mark>
Wurrumiyanga	24.9%	28.2%	23.7%	16.3%	16.6%	15.1%	14.7%	14.5%	16.9%	19.5%	19.5%	19.5%	19.1%
Gapuwiyak	20.7%	18.9%	20.8%	17.0%	11.8%	12.8%	10.1%	3.7%	11.4%	14.5%	16.6%	16.3%	14.6%
Gunbalanya	15.1%	18.0%	17.6%	16.6%	15.9%	14.5%	15.7%	16.5%	17.9%	16.0%	14.2%	16.0%	16.2%



LOW LOAD and ENGINES

- Damaged Engines
- I Caterpillar C9
- I Cummins QSK23
- I Caterpillar 3508

- Exercise period needed after low load
- Delay low load at start of life
- Targeted sizing, good for production, limits operation


Wurrumiyanga

- Earth leakage
- Circuit breaker failure
- Temperature
- Undersized cables




Wurrumiyanga

Overvoltage shutdown




Power and Water Corporation


Elspec DFR 15 minute sample



Elspec DFR 3 minute sample



Elspec DFR 1 second sample






Daly River

Titjikala 🗸






Operation

- Diesel On Grid Following
- Droop Transitions
- Isochronous Diesel Off

- Delayed Discharge
- Standby mode
- Switching losses



Power and Water Corporation


Single points of failure

- Pre Charge Rack
- Cooling System

BESS maintenance

- Filters
- Cooling system
- Capacity test





Round Trip Efficiency

Daly River

- 90.9 Excluding ancillaries
- 89.8 Including ancillaries

Titjikala

- 92.1 Excluding ancillaries
- 88.7 Including ancillaries

Titjikala

- Remote Commissioning
- Base Load
- CanBus latency





Thank you

Questions

Jeff Adams

Jeff.adams@powerwater.com.au

